

Our Ref: HL/M120192
Test Report: MA4505/G

28th October 2013

Rich. Klinger Dichtungstechnik GmbH & Co. KG.
Am Kanal 8 – 10,
2352 Gumpoldskirchen,
Austria

WATER REGULATIONS ADVISORY SCHEME (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS 6920-1:2000 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

FIBRE

5075

Klingersil C – 4324. Fibre/rubber gasket material, green coloured on one side and grey coloured on the other, manufactured by calendaring. Shore hardness 65. For use with water up to 85°C.
For use only as a jointing/gasket material having been tested at a reduced surface area to volume ratio.

APPROVAL NUMBER: 1205521


APPROVAL HOLDER: RICH. KLINGER DICHTUNGSTECHNIK GMBH & CO. KG.

The Scheme reserves the right to review approval. This approval is valid between May 2012 and May 2017.

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully



Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme